

Statement for the CEMS results – January 2017

On the 11th January 2017 between 13:30-14:59 the CEMS instrument for the half hour average of Volatile Organic Carbon (VOC) recorded reading of 20.27, 21.44 and 21.64 mg/m³. At the period of time the Clinical Waste Incinerator CEMS FID equipment was on maintenance, replacing H₂/He gas bottle and investigating the unreasonable level of VOC, consequently, this reading does not constitute a breach of any emission limit within the EPR Permit, nor does it indicate that the plant was performing abnormally.

A handwritten signature in blue ink, appearing to be 'G. J.', is centered on a light blue rectangular background.

Signed:

Date: 16th January 2017