


Statement for the CEMS results – January 2010

On 8th January 2010 between 21:00 and 21:29 the CEMS instrument for the half hour average of Sulphur-dioxide (SO₂) recorded reading of 329.27 mg/Nm³. The reason was the higher level of the Sulphuric content of the waste. To reduce the level of emission lime quantity was increased immediately to the bag filter house.

A handwritten signature in blue ink, appearing to be 'GJ', is centered on a small white rectangular background.

Signed:

Date: 12th January 2010