


Permit Reference Number : EPR/BT2866/V003 Operator : Grundon Waste Management Limited

Installation: CWI, Lakeside Road, Colnbrook, Slough, SL3 0EG. Form Number: S3/A/1

Reporting of Continuously Monitored Emissions to Air for CO mg/m³ at Emission Point A1 For the month of January 2010



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
10 Minute average		10 Minute average ELV	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	150.0	
	Monthly maximum	49.7	95 %ile 10 Minute average		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	4.3	24.1	19.3	49.7	22.7	29.5	47.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly mean	7.7	Mean 10 Minute average		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.6	6.0	5.9	12.5	6.0	8.0	11.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Monthly minimum	0.0	Minimum 10 Minute average		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	1.7	2.0	1.3	1.6	0.0	0.0	0.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	Total Invalid results	0	No of Invalid results		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Sum of exceedances	0	No of exceedances of ELV		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Daily average		Daily average ELV	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	50.0	
	Monthly maximum	12.5	Daily average		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.6	6.0	5.9	12.1	6.0	7.7	11.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	No of invalid days	0	Value Valid?		Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y		
	Sum of exceedances	0	Value Exceeds ELV?		N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	

Signed..... Date.....
 (Authorised to sign as a representative of the Operator)