

Statement for the CEMS results – August 2010

On 1st August 2010 between 05:30-06:59 the CEMS instrument for the half hour average of Volatile Organic Carbon (VOC) recorded reading of 112.12, 166.74 and 33.92 mg/m³. This time the CEMS FID equipment was under maintenance, replacing gas bottle, consequently this reading does not constitute a breach of any emission limit within the EPR Permit, nor does it indicate that the plant was performing abnormally.

Signed:

A handwritten signature in blue ink, consisting of a stylized 'G' followed by a vertical line and a horizontal line, resembling a cross or a specific monogram.

Date: 9th August 2010